



PORTABLE APPLIANCE TESTING REPORT

JV Hire Services Ltd Unit 13 Enterprise Court Rankine Road Basingstoke RG24 8GE					REPORT NO.:		0003		 	
					DATE:		15/01/2019			
ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH Ohms	INSULATION Mohms				
0001	Fly Lead	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0002	Fly Lead	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0003	Fly Lead	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0004	Fly Lead	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0005	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0006	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0007	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0008	Fly Lead	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0009	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0010	Fly Lead	Warehouse	3	OK	0.14	>200	OK	15/01/2020	PASS	
0011	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0012	Fly Lead	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0013	Fly Lead	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0014	Fly Lead	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0015	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0016	Fly Lead	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0017	Fly Lead	Warehouse	3	OK	0.09	>200	OK	15/01/2020	PASS	
0018	Fly Lead	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0019	Fly Lead	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0020	Fly Lead	Warehouse	3	OK	0.09	>200	OK	15/01/2020	PASS	
0021	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0022	Fly Lead	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0023	Fly Lead	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0024	Fly Lead	Warehouse	3	OK	0.02	>200	OK	15/01/2020	PASS	
0025	Fly Lead	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0026	Fly Lead	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0027	Fly Lead	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0028	Fly Lead	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0029	IEC Cable	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0030	IEC Cable	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0031	4 Way Extension	Warehouse	3	OK	0.22	>200	OK	15/01/2020	PASS	
0032	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0033	Splitter	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0034	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0035	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0036	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0037	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0038	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0039	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0040	Splitter	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0041	Splitter	Warehouse	3	OK	0.02	>200	OK	15/01/2020	PASS	
0042	Ceeform to Socket	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0043	Ceeform to Socket	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0044	Ceeform to Socket	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0045	Ceeform to Socket	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0046	Ceeform to 4 Way	Warehouse	3	OK	0.21	>200	OK	15/01/2020	PASS	
0047	16a Extension	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0048	Splitter	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0049	16a Extension	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0050	16a Extension	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0051	Splitter	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0052	Ceeform to Socket	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0053	4 Way Extension	Warehouse	3	OK	0.18	>200	OK	15/01/2020	PASS	
0054	Blue 14m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0055	Blue 14m Extension	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0056	Blue 14m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0057	Blue 14m Extension	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0058	Blue 14m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0059	Blue 14m Extension	Warehouse	3	OK	0.14	>200	OK	15/01/2020	PASS	
0060	Blue 14m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0061	Blue 14m Extension	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0062	25m Fly Lead	Warehouse	3	OK	0.39	>200	OK	15/01/2020	PASS	
0063	Orange 25m Extension	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0064	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0065	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0066	Orange 25m Extension	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0067	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0068	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0069	Orange 25m Extension	Warehouse	3	OK	0.22	>200	OK	15/01/2020	PASS	
0070	Orange 25m Extension	Warehouse	3	OK	0.30	>200	OK	15/01/2020	PASS	
0071	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0072	Orange 25m Extension	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0073	Orange 25m Extension	Warehouse	3	OK	0.30	>200	OK	15/01/2020	PASS	
0074	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0075	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0076	Orange 25m Extension	Warehouse	3	OK	0.32	>200	OK	15/01/2020	PASS	
0077	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0078	Orange 25m Extension	Warehouse	3	OK	0.32	>200	OK	15/01/2020	PASS	
0079	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0080	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0081	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0082	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0083	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0084	Orange 25m Extension	Warehouse	3	OK	0.23	>200	OK	15/01/2020	PASS	
0085	Orange 25m Extension	Warehouse	3	OK	0.30	>200	OK	15/01/2020	PASS	
0086	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0087	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0088	Orange 25m Extension	Warehouse	3	OK	0.30	>200	OK	15/01/2020	PASS	
0089	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0090	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0091	Orange 25m Extension	Warehouse	3	OK	0.32	>200	OK	15/01/2020	PASS	
0092	Orange 25m Extension	Warehouse	3	OK	0.34	>200	OK	15/01/2020	PASS	
0093	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0094	Orange 25m Extension	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0095	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0096	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0097	Orange 25m Extension	Warehouse	3	OK	0.23	>200	OK	15/01/2020	PASS	
0098	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0099	Orange 25m Extension	Warehouse	3	OK	0.36	>200	OK	15/01/2020	PASS	
0100	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0101	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0102	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0103	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0104	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0105	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0106	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0107	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0108	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0109	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0110	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0111	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0112	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0113	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0114	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0115	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0116	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0117	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0118	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0119	Orange 25m Extension	Warehouse	3	OK	0.31	>200	OK	15/01/2020	PASS	
0120	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0121	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0122	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0123	Orange 25m Extension	Warehouse	3	OK	0.21	>200	OK	15/01/2020	PASS	
0124	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0125	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0126	Orange 25m Extension	Warehouse	3	OK	0.30	>200	OK	15/01/2020	PASS	
0127	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0128	Orange 25m Extension	Warehouse	3	OK	0.19	>200	OK	15/01/2020	PASS	
0129	Orange 25m Extension	Warehouse	3	OK	0.20	>200	OK	15/01/2020	PASS	
0130	Orange 25m Extension	Warehouse	3	OK	0.33	>200	OK	15/01/2020	PASS	
0131	Fly Lead	Warehouse	3	OK	0.02	>200	OK	15/01/2020	PASS	
0132	Fly Lead	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0133	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0134	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0135	2.0hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0136	2.0hp Fan	Warehouse	1	OK	0.06	>200	OK	15/01/2020	PASS	
0137	2.0hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0138	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0139	1.5hp Fan	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0140	1.5hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0141	1.5hp Fan	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0142	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0143	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0144	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0145	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0146	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0147	1.5hp Fan	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0148	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0149	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0150	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0151	1.5hp Fan	Warehouse	1	OK	0.07	>200	OK	15/01/2020	PASS	
0152	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0153	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0154	1.5hp Fan	Warehouse	1	OK	0.06	>200	OK	15/01/2020	PASS	
0155	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0156	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0157	1.5hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0158	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0159	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0160	1.5hp Fan	Warehouse	1	OK	0.07	>200	OK	15/01/2020	PASS	
0161	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0162	1.5hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0163	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0164	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0165	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0166	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0167	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0168	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0169	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0170	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0171	1.5hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0172	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0173	1.5hp Fan	Warehouse	1	OK	0.04	>200	OK	15/01/2020	PASS	
0174	1.5hp Fan	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0175	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0176	1.5hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0177	1.5hp Fan	Warehouse	1	OK	0.02	>200	OK	15/01/2020	PASS	
0178	0.75hp Fan	Warehouse	1	OK	0.06	>200	OK	15/01/2020	PASS	
0179	0.75hp Fan	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0180	25m Extension Reel	Warehouse	3	OK	0.45	>200	OK	15/01/2020	PASS	
0181	50m Extension Reel	Warehouse	3	OK	0.77	>200	OK	15/01/2020	PASS	
0182	50m Extension Reel	Warehouse	3	OK	0.79	>200	OK	15/01/2020	PASS	
0183	Ceeform to IEC	Office	3	OK	0.10	>200	OK	15/01/2020	PASS	
0184	50m Extension Reel	Warehouse	3	OK	0.79	>200	OK	15/01/2020	PASS	
0185	40m Extension Reel	Warehouse	3	OK	0.64	>200	OK	15/01/2020	PASS	
0186	15m Extension Reel	Warehouse	3	OK	0.29	>200	OK	15/01/2020	PASS	
0187	25m Extension Reel	Warehouse	3	OK	0.43	>200	OK	15/01/2020	PASS	
0188	Selfie Pod Camera	Kitchen	2	OK	N/A	>200	OK	15/01/2020	PASS	
0189	Selfie Fluorescent Light 1	Kitchen	1	OK	0.03	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0190	Selfie Fluorescent Light 2	Kitchen	1	OK	0.03	>200	OK	15/01/2020	PASS	
0191	Selfie Printer	Kitchen	1	OK	0.04	>200	OK	15/01/2020	PASS	
0192	IEC Cable	Kitchen	3	OK	0.09	>200	OK	15/01/2020	PASS	
0193	IEC Cable	Kitchen	3	OK	0.12	>200	OK	15/01/2020	PASS	
0194	6 Way Extension	Kitchen	3	OK	0.14	>200	OK	15/01/2020	PASS	
0195	Selfie Computer	Kitchen	1	OK	0.00	>200	OK	15/01/2020	PASS	
0196	iPad 1	Kitchen	2	OK	N/A	>200	OK	15/01/2020	PASS	
0197	iPad 2	Kitchen	2	OK	N/A	>200	OK	15/01/2020	PASS	
0198	iPad Charger	Kitchen	2	OK	N/A	>200	OK	15/01/2020	PASS	
0199	GSDM 1 Fluorescent Light 1	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0200	GSDM 1 Fluorescent Light 2	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0201	GSDM 1 Printer	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0202	4 Way Extension	Warehouse	3	OK	0.25	>200	OK	15/01/2020	PASS	
0203	8 Way Extension	Warehouse	3	OK	0.14	>200	OK	15/01/2020	PASS	
0204	GSDM 1 External Monitor	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0205	25m Extension Reel	Warehouse	3	OK	0.39	>200	OK	15/01/2020	PASS	
0206	GSDM 1 Camera	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0207	IEC Cable	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0208	IEC Cable	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0209	IEC Cable	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0210	IEC Cable	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0211	IEC Cable	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0212	IEC Cable	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0213	iPad Charger	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0214	iPad Charger	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0215	GSDM 1 Computer	Warehouse	1	OK	0.00	>200	OK	15/01/2020	PASS	
0216	GSDM 2 Fluorescent Light 1	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	
0217	GSDM 2 Fluorescent Light 2	Warehouse	1	OK	0.03	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0218	GSDM 2 Computer	Warehouse	1	OK	0.00	>200	OK	15/01/2020	PASS	
0219	25m Extension Reel	Warehouse	3	OK	0.40	>200	OK	15/01/2020	PASS	
0220	20m Extension Reel	Warehouse	3	OK	0.40	>200	OK	15/01/2020	PASS	
0221	GSDM 2 External Monitor	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0222	GSDM 2 Printer	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0223	8 Way Extension	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0224	GSDM 2 Camera	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0225	IEC Cable	Warehouse	3	OK	0.09	>200	OK	15/01/2020	PASS	
0226	IEC Cable	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0227	IEC Cable	Warehouse	3	OK	0.09	>200	OK	15/01/2020	PASS	
0228	GSDM 1 TV	Warehouse	1	OK	0.01	>200	OK	15/01/2020	PASS	
0229	GSDM 2 TV	Warehouse	1	OK	0.00	>200	OK	15/01/2020	PASS	
0230	ION Speaker 1	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0231	ION Speaker 2	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0232	ION Speaker 3	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0233	ION Speaker 4	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0234	IEC Cable	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0235	2,000w PA System	Warehouse	1	OK	0.05	>200	OK	15/01/2020	PASS	
0236	ION Party Speaker 1	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0237	ION Party Speaker 2	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0238	Disco Dome Light 1	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0239	Disco Dome Light 2	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0240	Fly Lead	Warehouse	3	OK	0.18	>200	OK	15/01/2020	PASS	
0241	Fuse Box	Warehouse	3	OK	0.14	>186	OK	15/01/2020	PASS	
0242	Fly Lead	Warehouse	3	OK	0.09	>200	OK	15/01/2020	PASS	
0243	Splitter	Warehouse	3	OK	0.21	>200	OK	15/01/2020	PASS	
0244	IEC to Ceeform	Warehouse	3	OK	0.12	>200	OK	15/01/2020	PASS	
0245	Ceeform to Socket	Warehouse	3	OK	0.14	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0246	Disco Dome Light 3	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0247	Disco Dome Light 4	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0248	25m Fly Lead	Warehouse	3	OK	0.37	>200	OK	15/01/2020	PASS	
0249	Fuse Box	Warehouse	3	OK	0.11	>200	OK	15/01/2020	PASS	
0250	Splitter	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0251	Ceeform to Socket	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0252	Ceeform to Socket	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0253	IEC Cable	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0254	Disco Dome Light 5	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0255	Disco Dome Light 6	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0256	Fly Lead	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0257	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0258	Fuse Box	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0259	IEC to Ceeform	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0260	Ceeform to Socket	Warehouse	3	OK	0.07	>200	OK	15/01/2020	PASS	
0261	Splitter	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0262	Disco Dome Light 7	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0263	Disco Dome Light 8	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0264	Fly Lead	Warehouse	3	OK	0.04	>200	OK	15/01/2020	PASS	
0265	Fly Lead	Warehouse	3	OK	0.06	>200	OK	15/01/2020	PASS	
0266	Splitter	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0267	Ceeform to Socket	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0268	IEC to Ceeform	Warehouse	3	OK	0.10	>200	OK	15/01/2020	PASS	
0269	Fuse Box	Warehouse	3	OK	0.08	>200	OK	15/01/2020	PASS	
0270	Sealed Air Pump	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0271	Sealed Air Pump	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0272	Water Pump	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0273	Sealed Air Pump	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
					Ohms	Mohms				
0274	Fly Lead	Warehouse	3	OK	0.12	>200	OK	15/01/2020	PASS	
0275	Splitter	Warehouse	3	OK	0.15	>200	OK	15/01/2020	PASS	
0276	Splitter	Warehouse	3	OK	0.12	>200	OK	15/01/2020	PASS	
0277	Ceeform to Socket	Warehouse	3	OK	0.13	>200	OK	15/01/2020	PASS	
0278	Floodlights on Stand	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0279	Smoke Machine	Warehouse	1	OK	0.07	>6.3	OK	15/01/2020	PASS	Heating Element
0280	Rodeo Control Panel	Warehouse	2	OK	N/A	>200	OK	15/01/2020	PASS	
0281	Fly Lead	Warehouse	3	OK	0.03	>200	OK	15/01/2020	PASS	
0282	Ceeform to Socket	Warehouse	3	OK	0.05	>200	OK	15/01/2020	PASS	
0283	IEC Cable	Kitchen	3	OK	0.08	>200	OK	15/01/2020	PASS	
0284	Candy Floss Machine	Kitchen	1	OK	0.04	>200	OK	15/01/2020	PASS	
0285	IEC Cable	Kitchen	3	OK	0.05	>200	OK	15/01/2020	PASS	
0286	Popcorn Machine	Kitchen	1	OK	0.04	>200	OK	15/01/2020	PASS	
0287	Kettle	Kitchen	1	OK	0.03	>200	OK	15/01/2020	PASS	
0288	Toaster	Kitchen	1	OK	0.08	>200	OK	15/01/2020	PASS	
0289	IEC	Office	3	OK	0.14	>200	OK	15/01/2020	PASS	
0290	IEC		3	OK	0.08	>200	OK	15/01/2020	PASS	
0291	IEC		3	OK	0.73	>200	OK	15/01/2020	PASS	
0292	IEC		3	OK	0.08	>200	OK	15/01/2020	PASS	
0293	IEC		3	OK	0.06	>200	OK	15/01/2020	PASS	

TOTAL APPLIANCES: 293

TEST ENGINEER SIGNATURE: 

TEST ENGINEER NAME: JOHN RANDALL